

CERTIFICATE

(Certificate of conformity with technical requirements in:)
API STANDARD 607 EIGHTH EDITION, OCTOBER 2022

Certificate No.: 327175

Ref. Test report No.: 327176

Name and postal address of manufacturer: **Wenzhou Tianyu Valve Technology Co., Ltd.**
Baoyi Village, Oubei Street, Yongjia County,
Wenzhou City, Zhejiang Province, PC: 325105, P. R. China

We hereby certify that the fire test on below valves have been conducted at the laboratory designated by manufacturer and witnessed by TÜV SÜD inspector according to requirements of API STANDARD 607 EIGHTH EDITION, OCTOBER 2022. The testing results of valves meet the requirements of API STANDARD 607 EIGHTH EDITION, OCTOBER 2022.

1. Description of Test Valve:

Type of Test Valve	NPS8 Class150 Butterfly Valve
Description of Test Valve	Butterfly Valve
Valve Size (NPS)	8"
Pressure Rating (Class)	Class 150
Valve Body Material	ASTM A216 WCB

2. Qualified Range of Valves :

Type	Butterfly Valves
Description of Valves	Butterfly Valves
Qualified Sizes (NPS) (according to API 607 Table 3)	8" and larger
Qualified Pressure Ratings(Class) (according to API 607 Table 4)	Class 150, Class 300
Qualified Valve Material	According to API 607 7.2
Remark: the technical data of tested valves see back of this certificate appendix 1.	

This certificate is issued according to API STANDARD 607 EIGHTH EDITION, OCTOBER 2022, based upon the result of testing report on above mentioned test valve. The additional valve qualification shall be limited on similar valves of same basic design and construction as the test valves and of the same nonmetallic materials as the test valve in the seat-to-closure member seal, seat-to-body seal, stem seal, and body joint seal according to API STANDARD 607 EIGHTH EDITION, OCTOBER 2022, Paragraph 7.

Shanghai, September 10, 2025
(Place, date)

Guilin Chen
TÜV SÜD Certification and Testing (China) Co., Ltd.
Floor 3-13, No.151, Heng Tong Road,
Shanghai, 200070, P. R. China

